

From: [R6HarveySITL](#)
To: [R6HarveyInfo](#)
Subject: FW: Daily USOR Response Summary
Date: Saturday, September 9, 2017 12:42:39 PM

From: Webster, Susan
Sent: Saturday, September 9, 2017 12:42:37 PM (UTC-06:00) Central Time (US & Canada)
To: R6HarveySITL
Cc: Hayes, Scott
Subject: Fwd: Daily USOR Response Summary

Fysa

Sent from my iPhone

Begin forwarded message:

From: "Adams, Adam" <Adams.Adam@epa.gov>
Date: September 9, 2017 at 11:38:52 AM CDT
To: "Meyer, John" <Meyer.John@epa.gov>
Cc: "Sanchez, Carlos" <sanchez.carlos@epa.gov>, "Josiam, Raji" <josiam.raji@epa.gov>, "Webster, Susan" <webster.susan@epa.gov>
Subject: Fwd: Daily USOR Response Summary

John, because this is a short update, I'm just forwarding.
Adam

Sent from my iPhone

Begin forwarded message:

From: Eric Pastor <eric.pastor@pbwllc.com>
Date: September 9, 2017 at 10:41:19 AM CDT
To: "Josiam, Raji" <josiam.raji@epa.gov>
Cc: "'Adams, Adam (<Adams.Adam@epa.gov>)' (<Adams.Adam@epa.gov>)" <Adams.Adam@epa.gov>, 'Joe Biss' <Joe.Biss@ehs-support.com>, Robert Coffman <rcoffman@ramboll.com>, "Ricardo Banda (<rbanda@ramboll.com>)" <rbanda@ramboll.com>, Lam Tran <Lam.Tran@tceq.texas.gov>, Matt Wickham <matt.wickham@pbwllc.com>, Roberta Russell <roberta.russell@pbwllc.com>, Frances Devore <Frances.Devore@pbwllc.com>
Subject: Daily USOR Response Summary

Hi Raji -

Here is today's USOR daily update:

Yesterday, 13 vacuum truck loads of water (approximately 65,000 gallons) were removed from the site, including two loads from the Chlorine Contact Tank (CCT), five loads from the Sand Filter, one load from the Aeration Basin (MCC East), one load from the Primary Clarifier (MCC East), and four loads from one of the two frac tanks temporarily staged on-site. Water was pumped from Lift Station #1 to a frac tank yesterday evening and again this morning so that the freeboard level in the lift station has been maintained at approximately 9 feet or more. Freeboard levels in the lift station will continue to be monitored over the weekend.

Also, as I mentioned in my report to you yesterday, damaged fence sections in the northwest corner of the MCC East property were repaired yesterday.

Please let me know if you have any questions or comments.

Thanks.

ERIC F. PASTOR, P.E.
PRINCIPAL ENGINEER

2201 DOUBLE CREEK DR., SUITE 4004
ROUND ROCK, TX 78664
O 512.671.3434 C 512.750.9582
eric.pastor@pbwllc.com
www.pbwllc.com



+++++CONFIDENTIALITY NOTICE+++++

This e-mail and the information contained herein may be confidential and/or protected by the attorney-client, work product or other applicable privilege. This e-mail is intended to be reviewed only by the individual or organization named above. If you are not the intended recipient or an authorized representative of the intended recipient, you are hereby notified that any review, dissemination, or copying of any portion of this e-mail, and/or any attachments, is prohibited. If you have received this e-mail in error, please immediately notify the sender by return e-mail and delete this e-mail from your system. Thank You.